



Our Ref. L-UCE/BEC/YITI-GS/GO/242/11

إشارة لنا :

Date: 09.07.2011

التاريخ:

Mr. Badri Narayanan
Project Manager
Bahwan Engineering Co. LLC.
P.O. Box 703, Ruwi, PC 112
Sultanate of Oman

Proj: Construction of 132/33KV Grid Station & Associated Transmission System
Yiti Area - Muscat Governorate (T.B. Tender No. 208/2008)

Sub: 132kV Cable Testing Vendor Approval

Dear Sir,

With reference to the above mentioned subject and BEC-UCE-208/2008/YITI-2011/161 dated 26/06/2011, along with the prequalification documents for Power Links International Co. L.L.C., please find UCE comments as follows:-


- M/s. Power Links Co. L.L.C. is approved as for 132kV cable testing.
- However, reference values according to standard should be indicated in the test protocols.

This is for BEC information and action

Thanking you, we remain,

For Universal Consulting Engineering LLC.

Refat Abdel Sattar Abdel Ghani
PROJECT /SITE MANAGER



cc: Strategic Planning & Projects manager (OETC)
cc: CEC (Cairo)