

JOB COMPLETION CERTIFICATE

EMERGENCY WORK

Project: Replacement of damaged cable bushing on emergency basis in 132kV Mulladah – MIS Feeder -2 at Mulladah Grid station

Contractor	POWER LINKS INTL CO LLC	Client	OMAN ELECTRICITY TRANSMISSION COMPANY S.A.O.C
OETC Ref.	OETC/338/2014 dated 05.11.2014		
Start Date	06-11-2014	End Date	23-11-2014

Job Title : Installation of 132kV ODSE termination and replacement of 132kV, 400mm² OHL conductor and CVT in 132kV Mulladah-MIS Feeder-2 at Mulladah Grid station

Location : Mulladah Grid Station

Feeder : MIS-2

Description of work:

- Cutting and removing of existing 132kV ODSE – 2 Nos
- Installation of 132kV 1C x 2000 Sqmm cable Termination – 2 Nos
- Replacement of 132kV, 400mm² OHL conductor
- Replacement of 132kV, CVT (ABB Make – CPA145) – 1 No
- Provision of 132kV Pfisterer certified jointer with Jointing/Termination tools
- Transportation of Pfisterer termination kit, 132kV - 400mm² OHL conductor and 132kV CVT from OETC store to Site and returning old materials
- Provision of scaffolding for ODSE termination


I hereby certify the work has been completed satisfactory and system is safe for operation.

On Behalf of PLI OMAN
Name: Vasanth P


TMP Engineer

On Behalf of OETC

Name: Ahmed Al Farsi


10/12/2014
Regional Transmission Manager


10/12/2014