

ENTEL LLC

No. : EPE-NCC-127/2015-16/410

Date: January 22, 2017.

M/s. Saudi National Contracting Co. LLC
PO Box 1413, Postal Code 130
Ghala, Muscat, Sultanate of Oman

Fax No: 244 94 146/24590034

Attn: Mr. Annamalai, Project Manager, SNCC

Project: Construction of 132/33 kV Uwaynat GS, 3rd 500 MVA TR at SIAS and 220 kV Cable from SPSS to SIAS (Tender number 127/2015)

Subject: Proposal of Sub-contractor for UG Cable installation and commissioning works- M/s Power links International Co LLC

Reference: 1. EPE-NCC-127/2015-16/397 Dated January 10, 2017.
2. DTF-127/2015-G-024A dated 17.01.2017

Compliance to the following comments which were made vide reference-1 are note noted.

1. Relevant documents to substantiate deployment of man power to the complete activity including testing and commissioning on project schedule shall be submitted. The above details shall include the manpower in each category such as engineers, supervisors and workers etc. with their qualification.
2. HSE plan with HSE Organization chart and HSE performance records of the sub-contractor shall be submitted for review.
3. Client/Consultant's certificate in support of satisfactory completion of previous projects.
4. In the DCRP certificate, it is noted the category as "11 KV OHL and UG cables..." But our project scope is 220 KV Cable. Please check and confirm this aspect.
5. Please check and confirm only ISO 9001 certification is available.
6. Please check and revise project specific applicable tools and tackles. The list is not appropriate to the project requirement.

The document is **recommended** for further action.

This is for your information and earliest necessary action.

Yours faithfully,



Samson Varughese
Project Manager

Co.: OETC - Senior Manager - Projects (Fax No. 24 493 416)